



Radar level measuring device for hygienic applications

- For level measurement up to 20 m
- 4... 20 mA/Hart 2 wires
- Adjustable via Display, key operation or PC-Tool with DTM
- ATEX approvals ⟨

Type 8138 can be combined with...



Process controller

Type 2103 Diaphragm valve

Type 8802-GD

control valve system

Element




Type 8644 Valve islands



The Type 8138 is a non-contact radar level measuring device for continuous level measurement.

It is particularly suitable for use in small vessels that contain beverage liquids under sanitary process conditions.



General data	
Materials	
Housing / Cover	PBT, Stainless steel 316L (1.4404) / PC
Seal ring / Ground terminal	NBR / Stainless steel 316Ti/316L (1.4571/1.4435)
Wetted parts	
Process connection / Antenna / Seal	Stainless steel 316L / TFM-PTFE / EPDM
Display*	LCD in full dot matrix (option)
Drocess connection	Clamp 9" DN95 connection adapted for GEA Tuckenhagen

Display*	LCD in full dot matrix (option)
Process connection	Clamp 2", DN25 connection adapted for GEA Tuchenhagen VARIN- LINE process connections, Flange DN50, DN100 DIN2501
Torque of the flange screws	60 Nm
Electrical connection	Cable glands M20 x 1.5
Measuring value	Distance between process connection and product surface
Min. dielectric figure	εr > 1.6
Dead zone	50 mm (from flange)
Measuring range	0.05 to 10 m (Clamp 2", DN25 connection or flange DN50 version) 0.05 to 20 m (flange DN100)
Process temperature with Clamp, flange connection with DN25 connection	-40 to +200 °C (-40 to 392 °F) -40 to +130 °C(-40 to 266 °F)
Vessel pressure with Clamp connection with DN25 connection	-1 to 16 bar (-14.51 to 232.16 PSI) (-100 to 1600 kPa)

rosso: prossure	
with Clamp connection	-1 to 16 bar (-14.51 to 232.16 PSI) (-100 to 1600 kPa)
with DN25 connection	-1 to 10 bar (-14.51 to 145.1 PSI) (-100 to 1000 kPa)
with flange connection	according to flange rules
Vibration resistance	Mechanical vibrations with 4 g and 5 100 Hz
Temperature coefficient	0.03 %/10K (Average temperature coefficient of the zero signal -
	temperature error)
Resolution	max. 1 mm
Frequency	K-band (26 GHZ technology)
Interval	approx. 1 s
Beam angle at 3 dB	18° (Measuring range 0.05 to 10 m)
	10° (Measuring range 0.05 to 20 m)
Adjustment time	> 1 s (dependent on the parameter adjustment)
Accuracy	±2 mm (see diagram)

^{*} to be ordered separately

Internal capacity Ci

Internal inductivity Li

1) homologation certificate PTB 08 ATEX 2002X

Electrical data				
	14 - 36 V DC or 14 - 30 V DC (Ex ia instrument)			
Operating voltage				
Permissible residual ripple	<100 Hz: Uss <1 V 100 Hz 10 kHz: Uss <10 mV			
Output signal	4 20 mA/HART			
Resolution	1.6 μΑ			
Fault signal	current output unchanged 20.5 mA, 22 mA or < 3.6 mA (selectable)			
Current limitation	22 mA			
Load	see load diagram			
Damping (63% of the input variable)	0 999 s, adjustable			
Environment				
Ambient temperature	-40 to +80 °C (-40 to 176 °F) (operation and storage)			
Relative humidity	80% max; without condensation			
Standards and approvals				
Protection	IP66/IP67 with M20 x 1.5 gland mounted and tightened			
Overvoltage category	III			
Protection class	II			
Standard EMC Security NAMUR Approvals	EN61326 EN61010-1 NE 21; NE 43 ATEX [®] : EN60079-0; EN60079-11; EN60079-26 FDA			
Specifications Ex				
🖾 - Protection	Categories 1/2G or 2G			
← Certification	Ex ia IIC T6			
Conformity specifications ¹⁾ Operating voltage Ui Short circuit rating li Power limitation Pi Ambient temperature	30 V 131 mA 983 mW -40 to +55 °C (-40 to 131 °F) (dependent on categories)			

negligible

negligible

Loa	ad diagram
Ω 1000	A
750)
500	
250	
	4
	14 16 18 20 22 24 26 28 30 32 34 36 V
1	HART load
2	Voltage limit Ex ia instrument
3	Voltage limit non-Ex instrument
4	Operating voltage



Target applications

In highly purified water


The manufacture of products, which are either injected directly into the bloodstream, or administered as nose or eye drops, requires high purity water (WFI). The measuring device 8138 is especially suitable for level measurement in the WFI storage tank. The contactless measurement is unaffected by pressure or vacuum. The front flush antenna of the Type 8138 guarantees optimum CIP and SIP cleaning results. The antenna is PTFE encapsulated to protect it against highly ionised water.



■ In the stirring and preparation vessel

Processes like yoghurt production take place in controlled, highly sterile surroundings. They therefore place heavy demands on the cleanability of all parts that touch the medium. The cleaning processes themselves are correspondingly thorough. Contamination with foreign bacteria would lead to spoilage of the entire batch.

The radar measuring device 8138 lends itself well for reliable level measurement here. The contactless measuring principle is not affected by the density changes in the yoghurt and the abrasiveness of the fruits. The front-flush antenna allows optimal CIP and SIP cleaning, is insensitive to high-pressure water jets and doesn't show thermal shock behaviour.





Principle of operation

The radar measuring device consists of an electronic housing, a process connection element the antenna and a sensor. The antenna emits short radar pulses with a duration of approximate 1 ns to the medium. These pulses are reflected by the medium surface and received by the antenna as echoes. Radar waves travel at the speed of light. The running time of the radar pulses from emission to reception is proportional to the distance and hence to the level. The determined level is converted into an output signal and transmitted as a measured value.

The measuring device can be adjusted with:

- the display/configuration module
- the suitable Bürkert DTM in conjunction with adjustment software according to the FDT/DTM standard, e.g. PACTware™ and PC
- a HART handheld

The entered parameters are generally saved in the measuring device Type 8138. Optionally, parameters may also be uploaded and downloaded with the display/configuration module or save in a file by using PACTware™/DTM

Set up with display/configuration module

The display/configuration module can be inserted into the measuring device and removed again at any time. It is not necessary to interrupt the power supply. The measuring device is adjusted via the four keys of the display/configuration module.



Set up with PACTware™/DTM and HART communication


The measuring device can be operated thanks to PACTware[™], via HART communication. An interface adapter is necessary for the adjustment with PACTware[™]. For the setup of the Type 8138, the DTM in the actual version must be used. The basic version of DTM incl. PACTware[™] is available as a free-of-charge download from the Internet at www.burkert.com.

Connecting the PC via HART

- 1. Measuring device 8138
- 2. HART-USB Modem
- 3. Resistance 250 Ohms


Necessary components:

- Measuring device 8138
- PC with PACTware[™] and suitable Bürkert DTM
- HART-USB Modem
- Resistance approx. 250 Ohms
- Power supply unit




burkert

Dimensions [mm]




burkert

Dimensions [mm]



burkert

Dimensions [mm]





Ordering chart for compact measuring device Type 8138

Specifications	Operating voltage	Output	Process connection	Electrical connection	Article no. without display/ configuration module
Standard version	14 - 36 V DC	4 20 mA/HART (2 wires)	Clamp 2"	Cable gland M20 x 1.5	560169 🚎
			DN25 connection adapted for GEA Tuchenhagen VARINLINE process connections	Cable gland M20 x 1.5	560171 📜
			Flange DN50 DIN2501 / 16 bar	Cable gland M20 x 1.5	560173 🚎
			Flange DN100 DIN2501 / 16 bar	Cable gland M20 x 1.5	560175 🛒
Ex version -	14 - 30 V DC	4 20 mA/HART	Clamp 2"	Cable gland M20 x 1.5	560170 📜
ATEX approval		(2 wires)	DN25 connection adapted for GEA Tuchenhagen VARINLINE process connections	Cable gland M20 x 1.5	560172 📜
			Flange DN50 DIN2501 / 16 bar	Cable gland M20 x 1.5	560174 📜
			Flange DN100 DIN2501 / 16 bar	Cable gland M20 x 1.5	560176 📜



Further versions on request



Process connection

Flange DN80 PN40 Form C DIN2501
DN150 PN16 Form C DIN2501
DN150 PN40 Form C DIN2501
2" 150 lb RF; ANSI B16.5
3" 150 lb RF; ANSI B16.5
4" 150 lb RF; ANSI B16.5
6" 150 lb RF; ANSI B16.5

Clamp 3"; 4"

Please also use the "request for quotation" on page 8 for ordering a customized measuring device. go to page

Ordering chart - accessories for measuring device Type 8138 (has to be ordered separately)

Specifications	Article no.
Set with 2 reductions M20 x 1.5/NPT1/2" + 2 neoprene flat seals for cable gland + 2 screw-plugs M20 x 1.5	551782 📜
Hart-USB Modem	560177 📜
Set with a display/configuration module, a transparent cover and a seal ring	559279 📜
Set with a transparent cover and a seal ring	561006 📜

In case of special application conditions, please consult for advice.



			- request for qu			Note
lease fill in and send to your	local Bürkert Sa	ales Centre	* with your inquiry or	order.		You can the fie
Company:			Contact person:			in the
Customer No.:			Department:			before out th
Address:			Tel. / Fax.:			
Postcode / Town:			E-mail:			
Radar level measuring device	8138 uantity:			Desired delivery	, date:	
Antenna	uantity.	Пгаса				(40 120 °C)
Process connection:	2"	□ Encaps	sulated horn (- 40 200 °C	□ 3"	encapsulated horn	(-40 130 C)
Bolting DIN 11851	DN50 PN	116,	☐ DN65 PN16	☐ DN80 P	N16	DN100 PN16
Hygienic fitting		on flange DN		with con	npression nut F40 Pl	N16
Aseptic Bolting DIN 11864-		ing at vessel)	DN60 (0-ring at vessel)-ring at vessel)	
SMS 1145		DN51		,	□ DN76	
Neuno Biocontrol) PN16			
Flange			PN40, Form C, DIN2501		2" 150 lb RF,	ANCI D16 E
rialige					3" 150 lb RF,	
			PN40, Form C, DIN2501			
		☐ DN100) PN40, Form C, DIN250	1	4" 150 lb RF,	ANSI B16.5
		DN150) PN40, Form C, DIN250	1	6" 150 lb RF,	ANSI B16.5
		□ DN200) PN40, Form C, DIN250	1	8" 150 lb RF,	ANSI B16.5
DN25 connection		☐ DN25	. PN10			
adapted for GEA Tuchenhagen VARINLINE Display/configuration modul		Yes	□No			
ATEX approval		Yes		approval	Yes	No
nterconnection possib	oilities with	other B	ürkert devices			
	e 2100 -le seat		Type 8138 - Radar level measuring device	Type 8110 - Level switch	PLC	

Subject to alteration.
© Christian Bürkert GmbH & Co. KG

1803/11_EU-en_00895043